

APPENIX – XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITRY CONDITION CERTIFICATE

No.

Date : 08/07/26

It is Certified that an inspection team headed by Mr. Paramveer Singh
(Name of Officers with designation) from Food Safety Officer
(Name of Department/Office) inspected the Vishwakarma Sen Secondary School Tappal
(Name & Address of the School) on 08/07/2026 (date of inspection) and found that the
Vishwakarma Sen Secondary School (Name of school) has safe drinking water
Facilities for the students and members of staff of the institution and is maintaining the hygienic
Sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T.Govt.

The above is valid for a period of 1 years / one year

Report code - W-110622-16

Signature with Seal: [Signature]
Name : Mr. Paramveer Singh
Designation : Food Safety Officer
Name & Address of the Office / Department:

To
Vishwakarma Senior Secondary School
Tappal Aligarh
(Name & Address of the Institution)





ITS LABORATORY

Laboratory: A-91, Sector-80, Phase-2, Noida, Gautam Budh Nagar - 201301, (U.P)

M.: 09911659800, 9305780312, 09958849764, 07210888634

Website: www.itslab.in, Email: contact@itslab.in, info@itslab.in, itrlab@gmail.com

An ISO 9001: 2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory



TC-6179

Report Code: W-110622-16, Page 1 of 2

TEST REPORT

Water Test Report

Report Code: W-110622-16

Issue Date: 28/06/2026

Issue To
VISHWAKARMA SENIOR SECONDARY SCHOOL
BAJNA ROAD TAPPAL, TEHSIL KHAIR, ALIGARH-202165 (U.P.)

SAMPLING & ANALYSIS DATA

Sample Received On : 23/06/2026
Sample Drawn By : Ashish (ITS Laboratory)
Sample Description : Drinking Water
Sample Drawn On : 22/06/2026
Sample Quantity : 1.0 Liter in Pet Cane for Chemical & 500ml for Microbiological in Sterilized Glass Bottle.
Analysis Duration : 22/06/2026 TO 28/06/2026

DRINKING WATER						
Essential test as per IS:10500-2012						
S.No.	Parameter	Test Method	Results	Units	Desirable Limit	Extended Limit
1.	pH	IS:3025(Part-11)	6.94	-	6.5 - 8.5	-
2.	Colour	IS:3025(Part-4)	<5.0	Hazen	5	25
3.	Turbidity	IS:3025(Part-05)	<1.0	NTU	5	10
4.	Total Hardness (as CaCO ₃)	IS:3025(Part-21)	22.2	mg/l	200	600
5.	Chloride(as Cl)	IS:3025(Part-32)	12.6	mg/l	250	1000
6.	Calcium (as Ca)	IS: 3025 (P- 40)	9.2	mg/l	75	200
7.	Iron (as Fe)	IS:3025(Part-53)	<0.05	mg/l	1.0	-
8.	Nitrate (as NO ₃)	IS: 3025 (P- 34)	<1.0	mg/l	45	No Relaxation
9.	Total Dissolved Solid	IS:3025(Part-16)	102	mg/l	500	2000
10.	Alkalinity (as CaCO ₃)	IS: 3025 (P- 23)	18.0	mg/l	200	600
11.	Fluoride (as F)	APHA 22nd edit	<0.1	mg/l	1.0	1.5
12.	Sulphate (as SO ₄)	IS: 3025 (P- 24)	2.26	mg/l	200	400
13.	Magnesium (as Mg)	IS: 3025 (P-46)	0.97	mg/l	30	100

CHECKED BY

AUTHORIZED SIGNATORY



Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will be destroyed after 30 days from the date of issue of the test reports unless otherwise specified. 3. Any complaints about this report should be communicated in writing within 7 days of this report. 4. Total liability of our laboratory is limited to invoiced amount.